Doppler Effects Measured in Fast Reactor Spectra at Cadarache.

- (a) SEFOR - fast transient measurements (high temp)
 SEFOR-1 - soft spectrum (beryllium moderation)
 SEFOR-2 - steel diluent pins - hard spectrum.
 Accuracy of measurements $\pm 15\%$.
- (b) SUPER-PHENIX isothermal temperature coefficient
 between $\sim 150\text{C}$ and 400C . Accuracy $\pm 10\%$
 (iron Doppler effect contributes about 10%)

Analyses

ECCO cell calculations modelling the whole subassembly, followed by BISTRO whole reactor calculations in cylindrical geometry JEF 2.2 cross section data.

Results

C/E values are well within the uncertainties

For the SUPER PHENIX analysis a Debye temperature of 300K has been assumed for UO_2 . This has an effect of 8.5%. For

Fe the Debye temperature is higher, $\sim 450\text{K}$ and this further modifies the effect.

C/E values.

SEFOR-1 0.96 $\pm$ 0.15.

SEFOR-2 1.04 $\pm$ 0.15

SUPER-PHENIX 1.00 $\pm$ 0.10

14100115

(+ Debye uncertainty effect)